

編號 : F 100 系所 : 機械工程學系甲組

科目 : 热力學

1. Consider a closed system for which any two of the pressure,  $p$ , the volume,  $V$ , and the temperature,  $T$ , may be chosen as the independent variables to define a thermodynamic equilibrium state. Prove the following:

(a) The specific heat at constant volume  $C_V = \left(\frac{\partial U}{\partial T}\right)_V$  and the specific heat at constant pressure  $C_p = \left(\frac{\partial H}{\partial T}\right)_p$  with  $U$  denoting the internal energy and  $H$  denoting the enthalpy;

$$(b) C_p - C_V = \left(\frac{\partial V}{\partial T}\right)_p \left\{ p + \left(\frac{\partial U}{\partial V}\right)_T \right\}. \quad (25 \text{ 分})$$

2. Calculate the entropy density (i.e. the entropy per unit volume) of the radiation field using the following relations

$$p = \frac{1}{3}u \quad \text{and} \quad u = \sigma T^4,$$

where  $p$  is the pressure,  $u$  is the internal energy per unit volume,  $\sigma > 0$  is a constant and  $T$  is the absolute temperature. Also draw the isothermal line and the isentropic line on the pressure-volume diagram. (25 分)

(背面仍有題目，請繼續作答)

3. (25 分) Answer the following questions:

- (a) What are Maxwell relations? (5 分)
- (b) What is Clapeyron equation? (5 分)
- (c) For a given pure substance, explain in detail, how the tables of thermodynamic properties in liquid and vapor phases can be developed from the experimental data? (15 分)

4. (25 分) Moist air at  $20^{\circ}\text{C}$ , 1.05 bars, 85 % relative humidity and a volumetric flow rate of  $0.3 \text{ m}^3/\text{s}$  enters a well-insulated compressor operating at a steady state. If moist air exits at  $100^{\circ}\text{C}$ , 2.0 bars, determine:

- (a) The relative humidity at the exit (%) ? (7 分)
- (b) The power input (KW) ? (8 分)
- (c) The rate of entropy production (KW/K) (10 分)

註：1. universal gas constant  $R = 8.314 \text{ KJ/mole K}$

2. 乾空氣(dry air) 分子量 = 28.97

3. 乾空氣之定壓比熱  $C_p = 1.004 \text{ KJ/Kg K}$

4. 水蒸氣之定壓比熱  $C_p = 1.872 \text{ KJ/Kg K}$

F 100 系所：機械工程學系甲組

科目：熱力學

 $H_2O$ 

## Saturated water—Temperature table

Temp., $T^{\circ}\text{C}$	Specific volume, $\text{m}^3/\text{kg}$			Internal energy, $\text{kJ/kg}$			Enthalpy, $\text{kJ/kg}$			Entropy, $\text{kJ/kg} \cdot \text{K}$		
	Sat. press., $P_{\text{sat}} \text{ kPa}$	Sat. liquid, $v_f$	Sat. vapor, $v_g$	Sat. liquid, $u_f$	Evap., $u_{fg}$	Sat. vapor, $u_g$	Sat. liquid, $h_f$	Evap., $h_{fg}$	Sat. vapor, $h_g$	Sat. liquid, $s_f$	Evap., $s_{fg}$	Sat. vapor, $s_g$
0.01	0.6113	0.001000	206.14	0.0	2375.3	2375.3	0.01	2501.3	2501.4	0.000	9.1562	9.1562
5	0.8721	0.001000	147.12	20.97	2361.3	2382.3	20.98	2489.6	2510.6	0.0761	8.9496	9.0257
10	1.2276	0.001000	106.38	42.00	2347.2	2389.2	42.01	2477.7	2519.8	0.1510	8.7498	8.9008
15	1.7051	0.001001	77.93	62.99	2333.1	2396.1	62.99	2465.9	2528.9	0.2245	8.5569	8.7814
20	2.339	0.001002	57.79	83.95	2319.0	2402.9	83.96	2454.1	2538.1	0.2966	8.3706	8.6672
25	3.169	0.001003	43.36	104.88	2304.9	2409.8	104.89	2442.3	2547.2	0.3674	8.1905	8.5580
30	4.246	0.001004	32.89	125.78	2290.8	2416.6	125.79	2430.5	2556.3	0.4369	8.0164	8.4533
35	5.628	0.001006	25.22	146.67	2276.7	2423.4	146.68	2418.6	2565.3	0.5053	7.8478	8.3531
40	7.384	0.001008	19.52	167.56	2262.6	2430.1	167.57	2406.7	2574.3	0.5725	7.6845	8.2570
45	9.593	0.001010	15.26	188.44	2248.4	2436.8	188.45	2394.8	2583.2	0.6387	7.5261	8.1648
50	12.349	0.001012	12.03	209.32	2234.2	2443.5	209.33	2382.7	2592.1	0.7038	7.3725	8.0763
55	15.758	0.001015	9.568	230.21	2219.9	2450.1	230.23	2370.7	2600.9	0.7679	7.2234	7.9913
60	19.940	0.001017	7.671	251.11	2205.5	2456.6	251.13	2358.5	2609.6	0.8312	7.0784	7.9096
65	25.03	0.001020	6.197	272.02	2191.1	2463.1	272.06	2346.2	2618.3	0.8935	6.9375	7.8310
70	31.19	0.001023	5.042	292.95	2176.6	2469.6	292.98	2333.8	2626.8	0.9549	6.8004	7.7553
75	38.58	0.001026	4.131	313.90	2162.0	2475.9	313.93	2321.4	2635.3	1.0155	6.6669	7.6824
80	47.39	0.001029	3.407	334.86	2147.4	2482.2	334.91	2308.8	2643.7	1.0753	6.5369	7.6122
85	57.83	0.001033	2.828	355.84	2132.6	2488.4	355.90	2296.0	2651.9	1.1343	6.4102	7.5445
90	70.14	0.001036	2.361	376.85	2117.7	2494.5	376.92	2283.2	2660.1	1.1925	6.2866	7.4791
95	84.55	0.001040	1.982	397.88	2102.7	2500.6	397.96	2270.2	2668.1	1.2500	6.1659	7.4159
Sat. press., MPa												
100	0.10135	0.001044	1.6729	418.94	2087.6	2506.5	419.04	2257.0	2676.1	1.3069	6.0480	7.3549
105	0.12082	0.001048	1.4194	440.02	2072.3	2512.4	440.15	2243.7	2683.8	1.3630	5.9328	7.2958
110	0.14327	0.001052	1.2102	461.14	2057.0	2518.1	461.30	2230.2	2691.5	1.4185	5.8202	7.2387
115	0.16906	0.001056	1.0366	482.30	2041.4	2523.7	482.48	2216.5	2699.0	1.4734	5.7100	7.1833
120	0.19853	0.001060	0.8919	503.50	2025.8	2529.3	503.71	2202.6	2706.3	1.5276	5.6020	7.1296
125	0.2321	0.001065	0.7706	524.74	2009.9	2534.6	524.99	2188.5	2713.5	1.5813	5.4962	7.0775
130	0.2701	0.001070	0.6685	546.02	1993.9	2539.9	546.31	2174.2	2720.5	1.6344	5.3925	7.0269
135	0.3130	0.001075	0.5822	567.35	1977.7	2545.0	567.69	2159.6	2727.3	1.6870	5.2907	6.9777
140	0.3613	0.001080	0.5089	588.74	1961.3	2550.0	589.13	2144.7	2733.9	1.7391	5.1908	6.9299
145	0.4154	0.001085	0.4463	610.18	1944.7	2554.9	610.63	2129.6	2740.3	1.7907	5.0926	6.8833
150	0.4758	0.001091	0.3928	631.68	1927.9	2559.5	632.20	2114.3	2746.5	1.8418	4.9960	6.8379
155	0.5431	0.001096	0.3468	653.24	1910.8	2564.1	653.84	2098.6	2752.4	1.8925	4.9010	6.7935
160	0.6178	0.001102	0.3071	674.87	1893.5	2568.4	675.55	2082.6	2758.1	1.9427	4.8075	6.7502
165	0.7005	0.001108	0.2727	696.56	1876.0	2572.5	697.34	2066.2	2763.5	1.9925	4.7153	6.7078
170	0.7917	0.001114	0.2428	718.33	1858.1	2576.5	719.21	2049.5	2768.7	2.0419	4.6244	6.6663
175	0.8920	0.001121	0.2168	740.17	1840.0	2580.2	741.17	2032.4	2773.6	2.0909	4.5347	6.6256
180	1.0021	0.001127	0.19405	762.09	1821.6	2583.7	763.22	2015.0	2778.2	2.1396	4.4461	6.5857
185	1.1227	0.001134	0.17409	784.10	1802.9	2587.0	785.37	1997.1	2782.4	2.1879	4.3586	6.5465
190	1.2544	0.001141	0.15654	806.19	1783.8	2590.0	807.62	1978.8	2786.4	2.2359	4.2720	6.5079
195	1.3978	0.001149	0.14105	828.37	1764.4	2592.8	829.98	1960.0	2790.0	2.2835	4.1863	6.4698