

※ 考生請注意：本試題 可 不可 使用計算機

- 1 Air enters a compressor operating at steady state at 27°C , 100 kPa and exits at a pressure of 0.6 MPa. Kinetic and potential energy changes can be ignored. If there are no internal irreversibilities, which of the following processes (i) adiabatic, (ii) polytropic with $n=1.2$, (iii) isothermal requires the minimum compressor work? Demonstrate your answer by evaluating the work per unit mass of air flowing for each case. Also, sketch the processes on the same P-v and T-s diagrams. Assume air is an ideal gas, with constant specific heat, $C_p = 1.004 \text{ kJ/kg}\cdot\text{K}$, $C_v = 0.717 \text{ kJ/kg}\cdot\text{K}$, and $R = 0.287 \text{ kJ/kg}\cdot\text{K}$. (30%)
- 2 (a) A gas is stored in a closed vessel at temperature T and pressure P_0 . Derive an expression for the specific availability (exergy) in terms of T , T_0 , and the specific heat C_p . The system is at rest and zero elevation relative to an availability (exergy) reference environment at pressure P_0 and temperature T_0 . Assume the ideal gas model with constant specific heat for the gas. (10%)
- (b) Repeat problem (a) for two gases, carbon dioxide and helium. Both gases have the same amount of mass. Which has the greater value for specific availability (exergy) to the same reference environment? The specific heat C_p of carbon dioxide is known to be smaller than that of helium. (10%)

(背面仍有題目,請繼續作答)

系所組別 機械工程學系甲組

考試科目 熱力學

考試日期 0307 節次 2

※ 考生請注意：本試題 可 不可 使用計算機

3. (25 分) Refrigerant - 134a enters the compressor of a refrigerator at 140 Kpa and -10°C at a rate of $0.3\text{m}^3/\text{min}$ and leaves at 1.0 Mpa. The isentropic efficiency of the compressor is 78%. The refrigerant enters the throttling valve at 0.95 Mpa and 30°C and leaves the evaporator as a saturated vapor at -18.5°C First, show the cycle on a T-s diagram and then determine:

- (1) the power input in the compressor (KW) (9 分)
- (2) the rate of heat removal from the refrigerated space (KW) (8 分)
- (3) the pressure drop (Kpa) and rate of heat gain (KW) in the line between the evaporator and compressor (8 分)

Saturated refrigerant-134a—Temperature table

Temp., $T^{\circ}\text{C}$	Press., P_{sat} MPa	Specific volume, m^3/kg		Internal energy, kJ/kg		Enthalpy, kJ/kg			Entropy, kJ/kg K	
		Sat. liquid, v_f	Sat. vapor v_g	Sat. liquid, u_f	Sat. vapor u_g	Sat. liquid, h_f	Evap., h_{fg}	Sat. vapor, h_g	Sat. liquid, s_f	Sat. vapor, s_g
-40	0.05164	0.0007055	0.3569	-0.04	204.45	0.00	222.88	222.88	0.0000	0.9560
-36	0.06332	0.0007113	0.2947	4.68	206.73	4.73	220.67	225.40	0.0201	0.9506
-32	0.07704	0.0007172	0.2451	9.47	209.01	9.52	218.37	227.90	0.0401	0.9456
-28	0.09305	0.0007233	0.2052	14.31	211.29	14.37	216.01	230.38	0.0600	0.9411
-26	0.10199	0.0007265	0.1882	16.75	212.43	16.82	214.80	231.62	0.0699	0.9390
-24	0.11160	0.0007296	0.1728	19.21	213.57	19.29	213.57	232.85	0.0798	0.9370
-22	0.12192	0.0007328	0.1590	21.68	214.70	21.77	212.32	234.08	0.0897	0.9351
-20	0.13299	0.0007361	0.1464	24.17	215.84	24.26	211.05	235.31	0.0996	0.9332
-18	0.14483	0.0007395	0.1350	26.67	216.97	26.77	209.76	236.53	0.1094	0.9315
-16	0.15748	0.0007428	0.1247	29.18	218.10	29.30	208.45	237.74	0.1192	0.9298
-12	0.18540	0.0007498	0.1068	34.25	220.36	34.39	205.77	240.15	0.1388	0.9267
-8	0.21704	0.0007569	0.0919	39.38	222.60	39.54	203.00	242.54	0.1583	0.9239
-4	0.25274	0.0007644	0.0794	44.56	224.84	44.75	200.15	244.90	0.1777	0.9213
0	0.29282	0.0007721	0.0689	49.79	227.06	50.02	197.21	247.23	0.1970	0.9190
4	0.33765	0.0007801	0.0600	55.08	229.27	55.35	194.19	249.53	0.2162	0.9169
8	0.38756	0.0007884	0.0525	60.43	231.46	60.73	191.07	251.80	0.2354	0.9150
12	0.44294	0.0007971	0.0460	65.83	233.63	66.18	187.85	254.03	0.2545	0.9132
16	0.50416	0.0008062	0.0405	71.29	235.78	71.69	184.52	256.22	0.2735	0.9116
20	0.57160	0.0008157	0.0358	76.80	237.91	77.26	181.09	258.35	0.2924	0.9102
24	0.64566	0.0008257	0.0317	82.37	240.01	82.90	177.55	260.45	0.3113	0.9089
26	0.68530	0.0008309	0.0298	85.18	241.05	85.75	175.73	261.48	0.3208	0.9082
28	0.72675	0.0008362	0.0281	88.00	242.08	88.61	173.89	262.50	0.3302	0.9076
30	0.77006	0.0008417	0.0265	90.84	243.10	91.49	172.00	263.50	0.3396	0.9070
32	0.81528	0.0008473	0.0250	93.70	244.12	94.39	170.09	264.48	0.3490	0.9064
34	0.86247	0.0008530	0.0236	96.58	245.12	97.31	168.14	265.45	0.3584	0.9058
36	0.91168	0.0008590	0.0223	99.47	246.11	100.25	166.15	266.40	0.3678	0.9053
38	0.96299	0.0008651	0.0210	102.38	247.09	103.21	164.12	267.33	0.3772	0.9047
40	1.0164	0.0008714	0.0199	105.30	248.06	106.19	162.05	268.24	0.3866	0.9041
42	1.0720	0.0008780	0.0188	108.25	249.02	109.19	159.94	269.14	0.3960	0.9035
44	1.1299	0.0008847	0.0177	111.22	249.96	112.22	157.79	270.01	0.4054	0.9030

系所組別 機械工程學系甲組

考試科目 熱力學

考試日期 0307 節次：2

※ 考生請注意：本試題 可 不可 使用計算機

Superheated refrigerant-134a

T °C	v m ³ /kg	u kJ/kg	h kJ/kg	s kJ/kg K	v m ³ /kg	u kJ/kg	h kJ/kg	s kJ/kg K	v m ³ /kg	u kJ/kg	h kJ/kg	s kJ/kg K
$P = 0.06 \text{ MPa } (T_{\text{sat}} = -37.07^\circ\text{C})$				$P = 0.10 \text{ MPa } (T_{\text{sat}} = -26.43^\circ\text{C})$				$P = 0.14 \text{ MPa } (T_{\text{sat}} = -18.80^\circ\text{C})$				
Sat.	0.31003	206.12	224.72	0.9520	0.19170	212.18	231.35	0.9395	0.13945	216.52	236.04	0.9322
-20	0.33536	217.86	237.98	1.0062	0.19770	216.77	236.54	0.9602				
-10	0.34992	224.97	245.96	1.0371	0.20686	224.01	244.70	0.9918	0.14549	223.03	243.40	0.9606
0	0.36433	232.24	254.10	1.0675	0.21587	231.41	252.99	1.0227	0.15219	230.55	251.86	0.9922
10	0.37861	239.69	262.41	1.0973	0.22473	238.96	261.43	1.0531	0.15875	238.21	260.43	1.0230
20	0.39279	247.32	270.89	1.1267	0.23349	246.67	270.02	1.0829	0.16520	246.01	269.13	1.0532
30	0.40688	255.12	279.53	1.1557	0.24216	254.54	278.76	1.1122	0.17155	253.96	277.97	1.0828
40	0.42091	263.10	288.35	1.1844	0.25076	262.58	287.66	1.1411	0.17783	262.06	286.96	1.1120
50	0.43487	271.25	297.34	1.2126	0.25930	270.79	296.72	1.1696	0.18404	270.32	296.09	1.1407
60	0.44879	279.58	306.51	1.2405	0.26779	279.16	305.94	1.1977	0.19020	278.74	305.37	1.1690
70	0.46266	288.08	315.84	1.2681	0.27623	287.70	315.32	1.2254	0.19633	287.32	314.80	1.1969
80	0.47650	296.75	325.34	1.2954	0.28464	296.40	324.87	1.2528	0.20241	296.06	324.39	1.2244
90	0.49031	305.58	335.00	1.3224	0.29302	305.27	334.57	1.2799	0.20846	304.95	334.14	1.2516
100									0.21449	314.01	344.04	1.2785

Superheated refrigerant-134a (Continued)

T °C	v m ³ /kg	u kJ/kg	h kJ/kg	s kJ/kg K	v m ³ /kg	u kJ/kg	h kJ/kg	s kJ/kg K	v m ³ /kg	u kJ/kg	h kJ/kg	s kJ/kg K
$P = 0.50 \text{ MPa } (T_{\text{sat}} = 15.74^\circ\text{C})$				$P = 0.60 \text{ MPa } (T_{\text{sat}} = 21.58^\circ\text{C})$				$P = 0.70 \text{ MPa } (T_{\text{sat}} = 26.72^\circ\text{C})$				
Sat.	0.04086	253.64	256.07	0.9117	0.03408	238.74	259.19	0.9097	0.02918	241.42	261.85	0.9080
20	0.04188	239.40	260.34	0.9264					0.02979	244.51	265.37	0.9197
30	0.04416	248.20	270.28	0.9597	0.03581	246.41	267.89	0.9388	0.03157	253.83	275.93	0.9539
40	0.04633	256.99	280.16	0.9918	0.03774	255.45	278.09	0.9719	0.03324	263.08	286.35	0.9867
50	0.04842	265.83	290.04	1.0229	0.03958	264.48	288.23	1.0037	0.03482	272.31	296.69	1.0182
60	0.05043	274.73	299.95	1.0531	0.04134	273.54	298.35	1.0346	0.03634	281.57	307.01	1.0487
70	0.05240	283.72	309.92	1.0825	0.04304	282.66	308.48	1.0645	0.03781	290.88	317.35	1.0784
80	0.05432	292.80	319.96	1.1114	0.04469	291.86	318.67	1.0938	0.03924	300.27	327.74	1.1074
90	0.05620	302.00	330.10	1.1397	0.04631	301.14	328.93	1.1225	0.04064	309.74	338.19	1.1358
100	0.05805	311.31	340.33	1.1675	0.04790	310.53	339.27	1.1505	0.04201	319.31	348.71	1.1637
110	0.05988	320.74	350.68	1.1949	0.04946	320.03	349.70	1.1781	0.04335	328.98	359.33	1.1919
120	0.06168	330.30	361.14	1.2218	0.05099	329.64	360.24	1.2053	0.04468	338.76	370.04	1.2179
130	0.06347	339.98	371.72	1.2484	0.05251	339.38	370.88	1.2320	0.04599	348.66	380.86	1.2444
140	0.06524	349.79	382.42	1.2746	0.05402	349.23	381.64	1.2584	0.04729	358.68	391.79	1.2706
150					0.05550	359.21	392.52	1.2844	0.04857	368.82	402.82	1.2963
160					0.05698	369.32	403.51	1.3100				
$P = 0.80 \text{ MPa } (T_{\text{sat}} = 31.33^\circ\text{C})$				$P = 0.90 \text{ MPa } (T_{\text{sat}} = 35.53^\circ\text{C})$				$P = 1.00 \text{ MPa } (T_{\text{sat}} = 39.39^\circ\text{C})$				
Sat.	0.02547	243.78	264.15	0.9066	0.02255	245.88	266.18	0.9054	0.02020	247.77	267.97	0.9043
40	0.02691	252.13	273.66	0.9374	0.02325	250.32	271.25	0.9217	0.02029	248.39	268.68	0.9066
50	0.02846	261.62	284.39	0.9711	0.02472	260.09	282.34	0.9566	0.02171	258.48	280.19	0.9428
60	0.02992	271.04	294.98	1.0034	0.02609	269.72	293.21	0.9897	0.02301	268.35	291.36	0.9768
70	0.03131	280.45	305.50	1.0345	0.02738	279.30	303.94	1.0214	0.02423	278.11	302.34	1.0093
80	0.03264	289.89	316.00	1.0647	0.02861	288.87	314.62	1.0521	0.02538	287.82	313.20	1.0405
90	0.03393	299.37	326.52	1.0940	0.02980	298.46	325.28	1.0819	0.02649	297.53	324.01	1.0707
100	0.03519	308.93	337.08	1.1227	0.03095	308.11	335.96	1.1109	0.02755	307.27	334.82	1.1000
110	0.03642	318.57	347.71	1.1508	0.03207	317.82	346.68	1.1392	0.02858	317.06	345.65	1.1286
120	0.03762	328.31	358.40	1.1784	0.03316	327.62	357.47	1.1670	0.02959	326.93	356.52	1.1567
130	0.03881	338.14	369.19	1.2055	0.03423	337.52	368.33	1.1943	0.03058	336.88	367.46	1.1841
140	0.03997	348.09	380.07	1.2321	0.03529	347.51	379.27	1.2211	0.03154	346.92	378.46	1.2111
150	0.04113	358.15	391.05	1.2584	0.03633	357.61	390.31	1.2475	0.03250	357.06	389.56	1.2376
160	0.04227	368.32	402.14	1.2843	0.03736	367.82	401.44	1.2735	0.03344	367.31	400.74	1.2638
170	0.04340	378.61	413.33	1.3098	0.03838	378.14	412.68	1.2992	0.03436	377.66	412.02	1.2895
180	0.04452	389.02	424.63	1.3351	0.03939	388.57	424.02	1.3245	0.03528	388.12	423.40	1.3149

(背面仍有題目,請繼續作答)

系所組別 機械工程學系甲組

考試科目 熱力學

考試日期 0307 節次 2

※ 考生請注意 本試題 可 不可 使用計算機

- 4 (25 分) Methane (CH_4) is burned completely with the stoichiometric amount of air during a steady state combustion process. If both the reactants and products are maintained at 25°C and 1 atm and the water in the products exists in the liquid form,
- (1) write the combustion equation (5 分)
 - (2) determine the air-fuel ratio (kg air/kg CH_4) (5 分)
 - (3) determine the heat transfer (KJ/kmole CH_4) from the combustion chamber during this process. (10 分)
 - (4) what would your answer be for the heat transfer (KJ /kmole CH_4) if combustion were achieved with 100 % excess air (5 分)

Enthalpy of formation, Gibbs function of formation, and absolute entropy at 25°C , 1 atm

Substance	Formula	\bar{h}_f° kJ/kmol	\bar{g}_f° kJ/kmol	S° kJ/kmol K
Carbon	$\text{C}(s)$	0	0	5.74
Hydrogen	$\text{H}_2(g)$	0	0	130.68
Nitrogen	$\text{N}_2(g)$	0	0	191.61
Oxygen	$\text{O}_2(g)$	0	0	205.04
Carbon monoxide	$\text{CO}(g)$	-110,530	-137,150	197.65
Carbon dioxide	$\text{CO}_2(g)$	-393,520	-394,360	213.80
Water vapor	$\text{H}_2\text{O}(g)$	-241,820	-228,590	188.83
Water	$\text{H}_2\text{O}(l)$	-285,830	-237,180	69.92
Hydrogen peroxide	$\text{H}_2\text{O}_2(g)$	-136,310	-105,600	232.63
Ammonia	$\text{NH}_3(g)$	-46,190	-16,590	192.33
Methane	$\text{CH}_4(g)$	-74,850	-50,790	186.16
Acetylene	$\text{C}_2\text{H}_2(g)$	+226,730	+209,170	200.85
Ethylene	$\text{C}_2\text{H}_4(g)$	+52,280	+68,120	219.83
Ethane	$\text{C}_2\text{H}_6(g)$	-84,680	-32,890	229.49
Propylene	$\text{C}_3\text{H}_6(g)$	+20,410	+62,720	266.94
Propane	$\text{C}_3\text{H}_8(g)$	-103,850	-23,490	269.91
n-Butane	$\text{C}_4\text{H}_{10}(g)$	-126,150	-15,710	310.12
n-Octane	$\text{C}_8\text{H}_{18}(g)$	-208,450	+16,530	466.73
n-Octane	$\text{C}_8\text{H}_{18}(l)$	-249,950	+6,610	360.79
n-Dodecane	$\text{C}_{12}\text{H}_{26}(g)$	-291,010	+50,150	622.83
Benzene	$\text{C}_6\text{H}_6(g)$	+82,930	+129,660	269.20
Methyl alcohol	$\text{CH}_3\text{OH}(g)$	-200,670	-162,000	239.70
Methyl alcohol	$\text{CH}_3\text{OH}(l)$	-238,660	-166,360	126.80
Ethyl alcohol	$\text{C}_2\text{H}_5\text{OH}(g)$	-235,310	-168,570	282.59
Ethyl alcohol	$\text{C}_2\text{H}_5\text{OH}(l)$	-277,690	-174,890	160.70
Oxygen	$\text{O}(g)$	+249,190	+231,770	161.06
Hydrogen	$\text{H}(g)$	+218,000	+203,290	114.72
Nitrogen	$\text{N}(g)$	+472,650	+455,510	153.30
Hydroxyl	$\text{OH}(g)$	+39,460	+34,280	183.70